



Vent pipe must be connected in upper quadrant of horizontal drain pipe approximately 20 pipe diameters or greater

A distance

B distance

Sewer Line In

Sewer Ejector

A – AAV can be located anywhere in between distance A
The AAV serving the vent for the sewer ejector shall be the same size as the vent. (Mini-vent can serve either 1-1/2 or 2” pipe size)

B = The B distance will vary according to the sewer ejector manufacturers instructions

Note: Air admittance valve must be accessible